

CARE AND MAINTENANCE

Thermostatic Pre Mixer 3/4

B&M SKU: ID09028.1-34 Idral code: 09028.1-34

Routine care

- Inspect at least annually, and more often where water quality is poor or unknown.
- Check temperature at the same outlet used for commissioning. Idral calls for a check against the original setting, with no more than 2 C change.
- Arrange strainer cleaning or cartridge replacement when needed. Isolate the supplies before servicing.
- Idral states that the non-return valves do not normally need servicing. Avoid unnecessary dismantling of the connections.
- Idral recommends replacing this safety valve at intervals no longer than five years.

Service

Use compatible replacement parts. Isolate the water supply before servicing a connected water fitting.