INSTALLATION GUIDANCE

Gooseneck Basin Tap - Clinic Lever

Bridgepoint SKU: ID02050-DC Idral code: 02050/DC

Pre-installation

• Operating pressure: See original Idral Technical Specification.

• Flush the supply pipework thoroughly before installation and use filtered water. In mineral-rich water, use a suitable water softener.

Installation

• Install the fitting through the prepared basin/deck opening with the supplied seals and fixing kit.

• Connect the water supplies without twisting or straining flexible/copper connections.

• Where flexible hoses are supplied, do not install them under tension, traction or sharp bending; maintain an approximate minimum bend radius of 90 mm and keep them accessible for inspection or replacement.

• Open the supply gradually, check all joints for leaks and confirm smooth lever operation.

Follow local plumbing regulations and use qualified personnel for installation and servicing.

Manufacturer source: Idral instruction ISTA38-01 for taps and mixers with ceramic-disc cartridges.